

Viral Filtration Efficiency (VFE) Final Report

Purchase Order:	EAM2020-20-5 PO / 007 /2020-2021	
Study Number:	1321908-S01	
Study Received Date:	18 Jul 2020	
Testing Facility:	Nelson Laboratories, LLC 6280 S. Redwood Rd.	
	Salt Lake City, UT 84123 U.S.A.	
Test Procedure(s): Deviation(s):	Standard Test Protocol (STP) Number: None	STP0007 Rev 16

Summary: The VFE test is performed to determine the filtration efficiency of test articles by comparing the viral control counts upstream of the test article to the counts downstream. A suspension of bacteriophage Φ X174 was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at 1.1 - 3.3 x 10³ plaque forming units (PFU) with a mean particle size (MPS) of 3.0 µm ± 0.3 µm. The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. The VFE test procedure was adapted from ASTM F2101.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side:	Lighter Side
Test Area:	~9.1 cm ²
VFE Flow Rate:	28.3 Liters per minute (L/min)
Conditioning Parameters:	85 \pm 5% relative humidity (RH) and 21 \pm 5°C for a minimum of 4 hours
Positive Control Average:	2.0 x 10 ³ PFU
Negative Monitor Count:	<1 PFU
MPS:	2.9 µm



James Luskin electronically approved

Study Director

James Luskin

13 Sep 2020 16:09 (+00:00) Study Completion Date and Time

I

ks



Results:

Test Date:

Test Article Number	Percent VFE (%)
1	98.8
2	99.4
3	98.9
4	98.2
5	99.5

The filtration efficiency percentages were calculated using the following equation:

$$\% VFE = \frac{C-T}{C} x \ 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article Note: The plate count total is available upon request

Page 2 of 2

ks